Accident / Incident Report Closed



Unit/Department Process Area		S	ite	Report Number	
North Operations-Elyria	The second secon	E	LYRIA	0084-NOPS-14-0067	
Report Date	rt Date Incident Date		icident Time	Copied From	
05/09/2014	/09/2014 05/09/2014		8:30 PM	er inne de service de la commencia e la commencia de la commencia de la commencia de servicio de la commencia d	
Incident Location	·	Т	eam Leader / Supervisor	Reported By	
North end Old Wyssmont area		R	aymond A Navarro	William Otero	
Title of Event (Limit to 90 characters)		C	ategory	Division / Bus. Group / Subgroup Code	
Bent and Twisted shaft on rotolock - Wyssmont		ont	Safety & Health Environmental	CC / G-CCP	
Incident Classification			· · · · · · · · · · · · · · · · · · ·		
Near Miss	⊠ Prope	rtv Loss	Contractor		
Process Safety		on / NOV	Contractor Ir	niury / Illness	
☐ Injury / Illness	P4	1 Exposure	Contract Inju		
Spill / Release	☐ Inspec	•	☐ PSM	•	
Permit / Regulatory Deviatio	_ '		Plant Upset		
Fire	☐ Non-C	Occupational	☐ EHS Manage	ement System Failure	
Odor Complaint	RMP		Other		
Describe Event / What Happene	ed .				
shaft that protrudes from the	mont on the nor Rotolock was n	rth end operations	. GL on duty climbed the	ladders and discovered that the	
Immediate Corrective Action or					
Advised North end operations repaired / replaced (93413703)		d Chuck Evans via	text and pictures). Wrot	e work notification to have shaft	
Immediate Cause					
Under investigation.					
Cause Narrative					
A contractor working in the ar rotary air valve.	ea mìsplaced a	ratchet that subse	quently fell into the hop	per then became lodged in the	
Contributing Causes		Root/Primary Cau	ses		
Contractor failed to secure the to in the area during an unrelated r	epair.	208 - Personal Performance	208 - Personal Performance	208 - Personal Performance	
Corrective actions from prior All implemented. Overloads were d oversized but were not yet repla	etermined to be	55 - Administrative/Ma gement Systems	78 - Problem na Identification/Contro	84 - Corrective Actions Not Yet Implemented	
Explanation of Root Causes					
208/208/208 - Contractor realiz was verified with the contract				this or raise the concern. This cussed with him the incident.	
55/78/84 - Electrical overloads previous AIM with an Action if protection devices were review After the 3rd incident, an elect heaters were previously down	em. After the 2r wed - the answe trician looked at	nd incident, the ma er was yes, they we t the electrical and	aintenance supervisor w ould have checked that v I lowered the fuse size fr	as asked if the electrical when they replaced the valve.	
Any known or potential off-site in		ممستعاو بتيمين	ncident? No	Estimated Cost: 2,000.00 USD	


Printed: 09/28/2016

Ite m	Corrective Action(s) to prevent recurrence	Responsible Person	Target Date	Final Closed Date	VC Re q	VE Re
1	Review with contractors and maintenance staff in monthly safety meetings and 5 minute safety talks; the importance of being aware of equipment running in departments while performing repairs or maintenance.	Stefan J Niewiadomski/BASF-CATALYSTS/B ASF	08/30/2014	09/30/2014	N	N

Approved By:	
Manager / Dept. Head Abdallah Ahmed 06/02/2014 02:10 PM	
EHS Unit Coordinator Jason M Therrien 06/02/2014 01:29 PM	
Confidential	



CONFIDENTIAL BASF_114_000064



CONFIDENTIAL BASF_114_000066